

Two Phase (Two Leg) Installation, U.S
For Filtering All Power From Utility.
 This Configuration Utilizes A Dedicated
 Circuit Breaker, At or Below The
 Current Rating Of The IND Line Inductor.
Do Not Connect IND Line Inductor To Utility
Without A Dedicated Intervening Circuit Breaker.

