

# Two Phase (Two Leg) Installation, U.S For Filtering All Power From Utility, 100 amp Service.

This Configuration Utilizes A Dedicated  
Circuit Breaker, At or Below The  
Current Rating Of The IND Line Inductor.

**Do Not Connect IND Line Inductor To Utility  
Without A Dedicated Intervening Circuit Breaker.**

