

Two Phase (Two Leg) Installation, U.S For Filtering All Power From Utility, 200 amp Service.

This Configuration Utilizes A Dedicated
Circuit Breaker, At or Below The
Current Rating Of The IND Line Inductor.

**Do Not Connect IND Line Inductor To Utility
Without A Dedicated Intervening Circuit Breaker.**

